

## PRODUCT CATALOG – BUILDING WIRE (Type Service Entrance Cable Type SE, Style SER, 600 Volt)

Size A WG and Conductors	Stranding Phase Cond. & Neutral	Bare Ground	Outside Diameter (Inches)	Lbs/1000 Ft.
<b>Three Conductor</b>				
6-6-6	7		.672	174
4-4-4	7		.737	229
3-3-3	7		.791	267
2-2-2	7		.858	318
1-1-1	19		.968	403
1/0-1/0-1/0	19		1.048	474
2/0-2/0-2/0	19		1.136	578
3/0-3/0-3/0	19		1.238	697
4/0-4/0-4/0	19		1.352	836
<b>Four Conductor (Reduced Neutral)</b>				
6-6-6-6	7	7	.708	202
4-4-4-6	7	7	.814	257
3-3-3-5	7	7	.874	306
2-2-2-4	7	7	.949	365
1-1-1-3	19	7	1.072	458
1/0-1/0-1/0-2	19	7	1.161	543
2/0-2/0-2/0-1	19	19	1.260	665
3/0-3/0-3/0-1/0	19	19	1.374	805
4/0-4/0-4/0-2/0	19	19	1.502	969

To determine ampacity by conductor size, please consult the National Electric Code, latest edition. Standards: UIL Standard 44, UIL Standard 854, Federal Specification JC-30B, NEC. Packaging: Per customer requirements.

Cutting charges apply to reels cut to order

The above data are approximate and subject to normal manufacturing tolerances.